


Direction A




MODEL	A		B		VOLUME			DOME VOLUME			STRAIGHT WALL AREA		WEIGHT	
	mm	inch	mm	inch	liters	U.S. gal	cubic FT	liters	U.S. gal	cubic FT	sq. m	sq. FT	Kg	LBS
63x67	2044±15	80.47±0.59	728	28.66	2451	647.56	86.61	511	135.0	18.06	3.62	38.97	306	673
63x86	2475±15	97.44±0.59	1158	45.59	3306	873.45	116.82	511	135.0	18.06	5.76	62.0	360	792

Direction A

1:5

[12-±0.35] 12-ø9 Through-hole
NOT ORIENTATED, TOP AND BOTTOM
FLANGE ARE NOT ALIGNED.



NOTES:

- TANK MUST MEET ALL APPLICABLE SPECIFICATIONS OF NSF/ANSI 044 STANDARD, LATEST REVISION.
- OPERATING SPECIFICATIONS:
 - MAXIMUM WORKING PRESSURE - 150 PSI (10.5 BAR)
 - TEMPERATURE RANGE - 34-150° F (1-65°C)
 - MAXIMUM VACUUM - 5"Hg (127mm Hg)
- VISUAL LINER INSPECTION
 - NO MORE THAN 20 INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS.
 - NO INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS LARGER THAN 5×5mm.
 - NO INTERNAL BLEMISHES OR BURNT DEBRIS ALLOWED.
- ALL GLASS STRANDS FROM FIBERGLASS LINER TO BE BONDED AND COVERED.
- SURFACE TO BE FREE OF NICKS, SCRATCHES, RESIN AND GLASS.
- SURFACE FINISH.
- DIMENSIONS IN PARENTHESIS ARE REFERENCE ONLY.
- DIMENSIONS IN SQUARE PARENTHESIS ARE INCH UNTI.
- TANK TO BE BONDED TO BASE.
- USING A STANDARD LEVEL WITH TANK POSITIONED ON A LEVEL SURFACE, DATUM B TO BE PARALLEL WITH DATUM A. BUBBLE OF LEVEL MUST FALL COMPLETELY WITHIN LINES WHEN MEASURED AT 90° INTERVALS WHEN PLACED ON THE TOP OF THE FLANGE.
- AFTER THE TANK IS LEVELED, IT IS RECOMMENDED THAT THE TANK BE BOLTED TO THE FLOOR IN SIX POSITIONS PER THE TRIPOD BASE BOLT HOLE PATTERN WITH 3/8" ANCHORS.

LENNTech
info@lenntech.com Tel. +31-152-610-900
www.lenntech.com Fax. +31-152-616-289

2	DIMENSION A CHANGED			2011/08/29		
1	THIS DRAWING IS UPDATED COMPLYING WITH THE CHINESE VERSION			2009/11/23		
VERSION NO.	DESCRIPTION OF CHANGES:			SIGNATURE	DATE	
REFERENTIAL PLASTIC SHRINKAGE (IF NECESSARY):			 WAVE CYBER (SHANGHAI) CO., LTD.			
SIGNATURE						
	NAME	DATE				
DESIGN						
INSPECTION						
APPROVAL						
THIS PRODUCT DRAWING CAN NOT BE COPIED AND/OR USED WITHOUT PRIOR WRITTEN APPROVAL OF WAVE CYBER.			SCALE	MATERIAL	MODEL	
			1 : 10		DESCRIPTION	
			QUANTITY	SMOOTHNESS	63" FRP PRESSURE VESSEL (DOUBLE FLANGE OPENING)	
			PROJECTION	COMPUTER CODE	DRAWING NO.	VERSION NO.
					113632-00	2
			DO NOT MEASURE THE DIMENSIONS.	UNIT: MM	TOTAL PAGE: 1	